



Fire Risk Assessment

Gill Sike House



HS.F.119 (rev03)

delivering promises, improving lives

Contents

1	Premises particulars	1
2	General statement of policy	1
3	Management system	1
4	General description of premises	2
5	Fire safety systems within the premises	4
6	Plan drawing	4
7	Identify fire hazards	4
8	Identify people at risk	5
9	Means of escape – horizontal evacuation.....	5
10	Means of escape – vertical evacuation.....	5
11	Fire safety signs and notices	5
12	Fire warning system	5
13	Emergency lighting system.....	5
14	Fire-fighting equipment.....	6
15	Management - maintenance.....	6
16	Method for calling the Fire Service	7
17	Emergency action plan	7
18	Training	7
19	Fire safety deficiencies to be rectified.....	7
20	Significant findings	8
21	Additional hazards.....	8
	Appendix A: Floor plans	9

Fire Risk Assessment

1 Premises particulars

Premises name: Gill Sike House

Use of premises: Domestic dwellings

Address: Thornbury Road, Wakefield

Owner / employer/ person in control of the workplace:

Phone No: 0345 8 507 507

Kevin Dodd, Chief Executive, WDH

Date of Risk Assessment:

May 2018

Date of Review:

May 2019

Name and relevant details of the person who carried out the Fire Risk Assessment:

Daniel Boardman, Property Compliance Manager CMIOSH

2 General statement of policy

Statement

Good health and safety is integral to good management. We aim to make sure that it continues to be part of the culture of WDH. Employees should have health, safety and welfare objectives agreed with managers and throughout WDH.

We recognise that complying with the Health and Safety at Work Act 1974, and the regulations made under it, is a legal duty, not a matter of choice. Our policy should exceed the minimum requirements of the law where possible and to do this we will provide sufficient resources to meet this commitment. We will also ensure that systems are in place that will allow us to maintain, monitor and continuously improve safety performance. Included in these systems will be the means to allow communication and consultation on health and safety matters between all levels within WDH.

This risk assessment only covers the common areas within the building and does not cover the inside of individual apartments.

3 Management system

Statement

The Fire Safety Policy is provided for all employees on our intranet Health and Safety pages. This confirms that a fire risk assessment will be undertaken on all premises to which the Regulatory Reform Order (RRO) applies.

The Property Compliance Manager has responsibility for fire safety issues which includes fire risk assessments and all matters relating to fire safety.

Inspection and servicing of dry riser systems are undertaken twice every year by Chubb engineers. Any repairs to a dry riser are carried out by our Specialist Services Team.

A programme is in place for the PAT testing of electrical equipment used by caretakers and cleaners.

Chubb fire services inspect and service all fire-fighting equipment in building.

All common areas are monitored by caretakers on a weekly basis to ensure they are kept sterile. Records are sent to our Property Compliance Team for filing and reporting to the Health and Safety Committee.

The entrance/exit security system provides for occupants to escape out of the fire exits by a fail to safe system.

4 General description of premises

Description

Gill Sike House is an 11 storey high rise residential building. It is a concrete and brick construction with block and beam floors at each level.

There are 87 apartments within the building, 43 one bedroom apartments and 44 two bedroom apartments.

Each storey is serviced by two lifts there are also stairways on each side of the building. (See plan Appendix A). The lifts have been fitted with a Fire Service key which allows the Fire Service to use the lifts in an emergency for the transporting of equipment to the fire bridge head.

There is a central refuse chute for tenants to dispose of refuse, the chute is fitted with a smoke activated closer at its outlet, this closes on activation by smoke and seals the chute to prevent smoke and fire entering the refuse chute shaft.

Each apartment has a 60 minute rated fire door fitted with intumescent strips to seal the door and prevent the spread of fire into common areas.

Where services pass horizontally and vertically throughout the building, these have been sealed with fire rated cement or other fire rated substances such as fire foam in hard to access places.

Windows on each landing can be opened and the Fire Service has access to the Fire Service key safe situated on the outside near the dry riser inlet cupboard. The Fire Service use the windows to clear smoke from common areas.

All common areas are kept clear of tenants personal belongings including mobility scooters, letters have been sent to tenants informing them of the requirement to ensure they do not store any personal belongings in common areas. Caretakers check compliance with this on a weekly basis and reports sent to our Property Compliance Team.

Hard wired smoke detection is provided in each apartment, tenants are informed by our leaflet 'Fire safety in high rise residential buildings' on action to take if there is a fire in their apartment. This information is also available on our website with instructions on what action tenants should take in an emergency. Notices displayed in the foyer reinforce this message.

This is reviewed annually and re-issued to tenants. Unless the tenants apartment is affected by fire or smoke they are advised to remain in their apartment.

Occupancy

Times the premises are in use: 24/7

The total number of persons employed within the premises at any one time: 1

The total number of persons who may reside in the premises at any one time: 160+

Size

Building footprint:

Number of storeys: Ground + 10

Number of stairs: 2

5 Fire safety systems within the premises

Fire warning system

Individual apartments have hard wired detection systems installed. There is no fire detection in the common areas.

Emergency lighting

Emergency lighting conforming to BS5266 provided throughout the building.

Fire doors

60 minute fire rated doors on apartment entrances and 30 minute fire rated doors in all communal areas.

Bin chute closers

Within each bin room a smoke activate closer shuts off the bin chutes and prevents smoke from entering the building.

Certificate up to date and available electronically.

Dry riser outlets

Not damaged or tampered with. Certificate up to date and available electronically

Sprinkler system

Yes No

Alarm system in corridors

Yes No

Key safe in place undamaged and full set of keys in place

Yes No

6 Plan drawing

Full set of drawings attached at end Appendix A.

7 Identify fire hazards

Sources of ignition

No hot works on premises, general electrical points present but these are subject to periodic testing in line with the Electrical Regulations 17th Edition.

Work processes:

Any hot works which would take place as part of the repair and maintenance within this building would be managed through the Hot Works Permit system currently in place.

Structural features that could promote the spread of fire: Include external cladding

Where service pass throughout the building these voids have fire rated, materials to prevent the spread of fire and smoke through the building.

Items stored within common areas

All clear

Is there gas piped into the building

No

8 Identify people at risk

Identify and specify the location of people at significant risk in case of fire, indicating why they are at risk, and what controls are or need to be in place.

Tenants, if their particular apartment was on fire. We have produced a leaflet for tenants titled 'Fire safety in high rise residential buildings', this provides tenants with actions to take if an emergency occurs within this building. This information is also available on our website with instructions on what action tenants should take in an emergency.

Information displayed in foyer informing tenants visitors on actions to take in case of fire.

9 Means of escape – horizontal evacuation

Stairways at either end of the corridors lead to ground storey and final exit door.

10 Means of escape – vertical evacuation

Commentary

Gill Sike House has a central lift area which is protected at each storey landing by fire rated doors. There are two stairways at each end of the wings (see plan at Appendix A) and common areas are maintained as sterile areas so the likelihood of a fire in the common area are low. Tenants would evacuate using the stairs which lead to a final exit door or the one to the rear of the building. See plans at Appendix A.

The entrance/exit security system provides for occupants to escape out of the fire exits by a fail to safe system.

11 Fire safety signs and notices

Commentary

The building has adequate number of signs which comply with the Safety Signs and Signals Regulations 1996. All exit routes adequately marked along with fire-fighting equipment. No Smoking signs displayed throughout the building.

Low level signage provided on stairwells to enable the Fire Service to identify which storey they are on if area is smoke filled.

12 Fire warning system

Commentary

Individual apartments have hard wired smoke detection.

13 Emergency lighting system

Commentary

The emergency lighting system is serviced and maintained in house, is adequate and meets the needs of the building. The system is serviced and tested by our Specialist Services engineers.

The system complies with BSEN60598.2.22.

14 Fire-fighting equipment

Commentary

Dry riser outlets are serviced twice a year and certificates available electronically.
All on site fire-fighting equipment has been serviced and certificates are available electronically.

15 Management - maintenance

Is there a maintenance programme for the fire safety provisions in the premises? **Yes**

Commentary **No**

Chubb undertake servicing and replacement of all fire-fighting equipment.

Smoke detectors are fitted in tenants apartments. Tenants are advised to test these regularly.

Are regular checks of fire exit doors, walls and partitions carried out? **Yes**

Commentary **No**

Carried out weekly as part of the caretakers checklist.

Are regular checks of escape routes and exit doors carried out? **Yes**

Commentary **No**

Carried out weekly as part of the caretakers checklist.

Are regular checks of fire safety signs carried out? **Yes**

Commentary **No**

Carried out weekly as part of the caretakers checklist.

Is there a maintenance regime for the fire warning system? **Yes**

Commentary **No**

Weekly by Facilities Management

Annually by in-house team and recorded

Is there a maintenance regime for the emergency lighting system? **Yes**

Commentary **Weekly** **No**

Six Monthly

Annually

Is there maintenance of the fire-fighting equipment by competent persons? **Yes**

Commentary **No**

Carried out weekly as part of the caretakers checklist.

Annually by in Chubb and recorded

Are records kept and their location identified? **Yes**

Commentary **No**

A set of CAD drawings are available for the building showing where fire-fighting equipment is located. (See Appendix A).

16 Method for calling the Fire Service

Specify

Tenants or the caretaker would call the Fire Service in the event of an emergency. Caretakers, if on site, would assist and inform OneCALL.

17 Emergency action plan

Commentary

Only tenants whose apartment is directly affected by fire would evacuate. All apartments have been compartmentalised with 60 minutes fire rated doors on apartment entrances and 30 minute fire rated doors in all communal areas and fire stoppage in place where services pass horizontally or vertically throughout the building.

Our tenants were all provided with a leaflet on sign up around fire safety in high rise residential buildings. This information is also available on our website with instructions on what action tenants should take in an emergency.

Notices in foyers also advise tenants on what action they should take in an emergency.

18 Training

Commentary

Training in fire safety is provided to our employees by the Health and Safety Team.

19 Fire safety deficiencies to be rectified

Deficiency and rectification	Priority	Date to be rectified	Responsibility	Date rectified
Ensure any areas which require actions are closed off				

Insert additional pages as required

20 Significant findings

Significant finding	Control measure and action
Insert additional pages as required	

21 Additional hazards

Specify

Need to consult Fire Service

Yes

No

Appendix A: Floor plans

